

PV Park
 2017 Bacteriological Results
 (Fecal Coliform Organisms/100ml)

Location/Date	23-May	30-May	6-Jun	13-Jun	20-Jun	27-Jun	6-Jul	11-Jul	18-Jul	20-Jul	21-Jul	25-Jul	1-Aug
PV Park													
Sample 103.1 Guard Chair North	<10	<10	<10	<10	30	10	40	40	10			<10	20
Sample 104 - Diving Board	<10	10	<10	<10	<10	<10	<10	10	<10			<10	10
Sample 106.1 - Guard Chair South	<10	10	<10	<10	<10	<10	<10	10	20			<10	<10
Sample 108.1 - Swim Lane	<10	<10	10	<10	10	<10	10	<10	>600	<10	<10	10	<10

High Rain Event within 24 hours of sampling

Regulatory Standard: <=200 organisms/100ml