

FEDERAL EMERGENCY MANAGEMENT AGENCY
NATIONAL FLOOD INSURANCE PROGRAM

O.M.B. No. 3067-0077
Expires July 31, 2002

ELEVATION CERTIFICATE

Important: Read the instructions on pages 1 - 7.

SECTION A - PROPERTY OWNER INFORMATION		For Insurance Company Use:
BUILDING OWNER'S NAME <u>CHARLIE DUBE</u>		Policy Number
BUILDING STREET ADDRESS (Including Apt., Unit, Suite, and/or Bldg. No.) OR P.O. ROUTE AND BOX NO. <u>10 RYAN LANE</u>		Company NAIC Number
CITY <u>PEQUANNOCK</u>	STATE <u>NJ</u>	ZIP CODE <u>07440</u>
PROPERTY DESCRIPTION (Lot and Block Numbers, Tax Parcel Number, Legal Description, etc.) <u>LOT 13 13 BLOCK 2602 2602</u>		
BUILDING USE (e.g., Residential, Non-residential, Addition, Accessory, etc. Use Comments section if necessary.) <u>RESIDENTIAL</u>		
LATITUDE/LONGITUDE (OPTIONAL) (#° - #' - ##.## or ##.####°)	HORIZONTAL DATUM: <input type="checkbox"/> NAD 1927 <input type="checkbox"/> NAD 1983	SOURCE: <input type="checkbox"/> GPS (Type): <input type="checkbox"/> USGS Quad Map <input checked="" type="checkbox"/> Other: <u>LOCAL (FILED MAP)</u>

SECTION B - FLOOD INSURANCE RATE MAP (FIRM) INFORMATION

B1. NFIP COMMUNITY NAME & COMMUNITY NUMBER <u>PEQUANNOCK TWP 345311</u>		B2. COUNTY NAME <u>MORRIS</u>		B3. STATE <u>NJ</u>	
B4. MAP AND PANEL NUMBER <u>0003</u>	B5. SUFFIX <u>C</u>	B6. FIRM INDEX DATE <u>9/17/92</u>	B7. FIRM PANEL EFFECTIVE/REVISED DATE <u>9/17/92</u>	B8. FLOOD ZONE(S) <u>AE</u>	B9. BASE FLOOD ELEVATION(S) (Zone AO, use depth of flooding) <u>184.0</u>

B10. Indicate the source of the Base Flood Elevation (BFE) data or base flood depth entered in B9.
 FIS Profile FIRM Community Determined Other (Describe): _____

B11. Indicate the elevation datum used for the BFE in B9: NGVD 1929 NAVD 1988 Other (Describe): _____

B12. Is the building located in a Coastal Barrier Resources System (CBRS) area or Otherwise Protected Area (OPA)? Yes No
Designation Date: _____

SECTION C - BUILDING ELEVATION INFORMATION (SURVEY REQUIRED)

C1. Building elevations are based on: Construction Drawings* Building Under Construction* Finished Construction
*A new Elevation Certificate will be required when construction of the building is complete.

C2. Building Diagram Number 1 (Select the building diagram most similar to the building for which this certificate is being completed - see pages 6 and 7. If no diagram accurately represents the building, provide a sketch or photograph.)

C3. Elevations - Zones A1-A30, AE, AH, A (with BFE), VE, V1-V30, V (with BFE), AR, AR/A, AR/AE, AR/A1-A30, AR/AH, AR/AO
Complete Items C3a-i below according to the building diagram specified in Item C2. State the datum used. If the datum is different from the datum used for the BFE in Section B, convert the datum to that used for the BFE. Show field measurements and datum conversion calculation. Use the space provided or the Comments area of Section D or Section G, as appropriate, to document the datum conversion.
Datum NGVD 29 Conversion/Comments _____

Elevation reference mark used BM ON SITE Does the elevation reference mark used appear on the FIRM? Yes No

<input type="checkbox"/> a) Top of bottom floor (including basement or enclosure)	<u>187.3</u> ft.(m)
<input type="checkbox"/> b) Top of next higher floor	<u>196.3</u> ft.(m)
<input type="checkbox"/> c) Bottom of lowest horizontal structural member (V zones only)	_____ ft.(m)
<input type="checkbox"/> d) Attached garage (top of slab)	<u>187.3</u> ft.(m)
<input type="checkbox"/> e) Lowest elevation of machinery and/or equipment servicing the building	_____ ft.(m)
<input type="checkbox"/> f) Lowest adjacent grade (LAG)	<u>187.2</u> ft.(m)
<input type="checkbox"/> g) Highest adjacent grade (HAG)	<u>192.0</u> ft.(m)
<input type="checkbox"/> h) No. of permanent openings (flood vents) within 1 ft. above adjacent grade	_____
<input type="checkbox"/> i) Total area of all permanent openings (flood vents) in C3h	_____ sq. in. (sq. cm)

SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION

This certification is to be signed and sealed by a land surveyor, engineer, or architect authorized by law to certify elevation information.
I certify that the information in Sections A, B, and C on this certificate represents my best efforts to interpret the data available.
I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.

CERTIFIER'S NAME <u>FRANK A. BEDNAREK, P.L.S.</u>	LICENSE NUMBER <u>38314</u>
TITLE <u>LAND SURVEYOR</u>	COMPANY NAME <u>BEDNAREK SURVEYING</u>
ADDRESS <u>1811 UNION VALLEY RD</u>	CITY <u>WEST MILFORD</u> STATE <u>NJ</u> ZIP CODE <u>07480</u>
SIGNATURE <u>[Signature]</u>	DATE <u>5/13/2000</u> TELEPHONE <u>973-728-8899</u>

MEMORANDUM

TO: Robert J. Grant
Construction Code Official

2602/13

FROM: Charles J. McKearnin, PE
Township Engineer
Director of Public Works



DATE: September 7, 2000

SUBJECT: Residential Construction -- Flood Plain Development
10 Ryan Lane
Block 301, Lot 39

Attached is a copy of the elevation certificate and as-built survey for 10 Ryan Lane, (Block 301, Lot 39). The 100-year flood elevation at this location is 184.00 feet. As per the attachment, the lowest floor elevation is 187.3 feet.

A site inspection was made and all site work appears to have been completed satisfactorily.

I have no objection to the issuance of a certificate of occupancy subject to your review.

attachment

cc: Planning Department ✓