

2402/5

FEDERAL EMERGENCY MANAGEMENT AGENCY
NATIONAL FLOOD INSURANCE PROGRAM

O.M.B. No. 3067-0077
Expires July 31, 2002

ELEVATION CERTIFICATE

Important: Read the instructions on pages 1 - 7.

SECTION A - PROPERTY OWNER INFORMATION

BUILDING OWNER'S NAME ANTHONY RUBINO		For Insurance Company Use: Policy Number	
BUILDING STREET ADDRESS (including Apt., Unit, Suite, and/or Bldg. No.) OR P.O. ROUTE AND BOX NO. 2 LUCY COURT		Company NAIC Number	
CITY POMPTON PLAINS	STATE NEW JERSEY	ZIP CODE 07444	
PROPERTY DESCRIPTION (Lot and Block Numbers, Tax Parcel Number, Legal Description, etc.) LOT 8-01 BLOCK 411 Block 2402 Lot 5			
BUILDING USE (e.g., Residential, Non-residential, Addition, Accessory, etc. Use a Comments area, if necessary.) RESIDENTIAL			
LATITUDE/LONGITUDE (OPTIONAL) (##° - ##' - ###.###" or ###.####")		HORIZONTAL DATUM: SOURCE: <input type="checkbox"/> GPS (Type): <input type="checkbox"/> USGS Quad Map <input checked="" type="checkbox"/> Other: NGVD 1929	

SECTION B - FLOOD INSURANCE RATE MAP (FIRM) INFORMATION

B1. NFIP COMMUNITY NAME & COMMUNITY NUMBER PEQUANNOCK TOWNSHIP 345311		B2. COUNTY NAME MORRIS		B3. STATE NEW JERSEY	
B4. MAP AND PANEL NUMBER 3453110003	B5. SUFFIX C	B6. FIRM INDEX DATE May 21, 1971	B7. FIRM PANEL EFFECTIVE/REVISED DATE Sept. 17, 1992	B8. FLOOD ZONE(S) AE	B9. BASE FLOOD ELEVATION(S) (Zone AO, use depth of flooding) 185.5

B10. Indicate the source of the Base Flood Elevation (BFE) data or base flood depth entered in B9.
 FIS Profile FIRM Community Determined Other (Describe): _____

B11. Indicate the elevation datum used for the BFE in B9: NGVD 1929 NAVD 1988 Other (Describe): _____

B12. Is the building located in a Coastal Barrier Resources System (CBRS) area or Otherwise Protected Area (OPA)? Yes No
 Designation Date: _____

SECTION C - BUILDING ELEVATION INFORMATION (SURVEY REQUIRED)

C1. Building elevations are based on: Construction Drawings* Building Under Construction* Finished Construction
 *A new Elevation Certificate will be required when construction of the building is complete.

C2. Building Diagram Number 1 (Select the building diagram most similar to the building for which this certificate is being completed - see pages 6 and 7. If no diagram accurately represents the building, provide a sketch or photograph.)

C3. Elevations -- Zones A1-A30, AE, AH, A (with BFE), VE, V1-V30, V (with BFE), AR, AR/A, AR/AE, AR/A1-A30, AR/AH, AR/AO
 Complete Items C3.a-i below according to the building diagram specified in Item C2. State the datum used. If the datum is different from the datum used for the BFE in Section B, convert the datum to that used for the BFE. Show field measurements and datum conversion calculation. Use the space provided or the Comments area of Section D or Section G, as appropriate, to document the datum conversion.
 Datum NGVD 1929 Conversion/Comments Local survey benchmark used.
 Elevation reference mark used 188.16 Does the elevation reference mark used appear on the FIRM? Yes No

<input type="checkbox"/> a) Top of bottom floor (including basement or enclosure) Garage=	<u>187.51</u> ft.(m)
<input type="checkbox"/> b) Top of next higher floor	<u>200.15</u> ft.(m)
<input type="checkbox"/> c) Bottom of lowest horizontal structural member (V zones only)	_____ ft.(m)
<input type="checkbox"/> d) Attached garage (top of slab)	<u>187.51</u> ft.(m)
<input type="checkbox"/> e) Lowest elevation of machinery and/or equipment servicing the building (Describe in a Comments area.)	<u>191.15</u> ft.(m)
<input type="checkbox"/> f) Lowest adjacent (finished) grade (LAG)	<u>186.85</u> ft.(m)
<input type="checkbox"/> g) Highest adjacent (finished) grade (HAG)	<u>188.09</u> ft.(m)
<input type="checkbox"/> h) No. of permanent openings (flood vents) within 1 ft. above adjacent grade	<u>N/A</u>
<input type="checkbox"/> i) Total area of all permanent openings (flood vents) in C3.h	<u>N/A</u> sq. in. (sq. cm)

SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION

This certification is to be signed and sealed by a land surveyor, engineer, or architect authorized by law to certify elevation information. I certify that the information in Sections A, B, and C on this certificate represents my best efforts to interpret the data available. I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.

TITLE: PRESIDENT, DARMOFALSKI ENGINEERING ASSOCIATES, INC.
 SIGNATURE: Paul P. Darmofalski DATE: 12/19/00
 COMPANY NAME: DARMOFALSKI ENGINEERING ASSOCIATES, INC.
 ADDRESS: 86 NEWARK POMPTON TURNPIKE, RIVERDALE, NEW JERSEY 07457
 TELEPHONE: (973) 835-8300
 LICENSE NUMBER: GE 24743

2402/5

MEMORANDUM

TO: Robert J. Grant
Construction Code Official

FROM: Charles J. McKearnin, PE
Township Engineer
Director of Public Works



DATE: January 10, 2001

SUBJECT: Certificate of Occupancy
Block 441, Lot 8.01
2 Lucy Court

I have reviewed the recently submitted elevation certificate and final grading plan (attached) prepared by Darmofalski Engineering Associates, Inc. for the above noted location and advise that the new construction complies with Township Flood Damage Prevention regulations.

The 100 year flood elevation is 185.5 feet and the lowest floor elevation (garage) is 187.51, as indicated on the provided documents.

Based on the above information, I have no objection to the issuance of a certificate of occupancy pending your review and that of the Planning Department.

Attachment

cc: Planning Department ✓